

ملاحظات

عليما ت المهندس الاستشاري :

☒ موافق ☐ غير موافق

التوقيع:

الاستلام : مندوب الما قول : التاريخ : / /



مكتب رمك للاستشارات الهندسية
Office Ramak For Engineering Consultancy
تعميم - إشراف - تخطيط عمراني - إدارة مشاريع



شركة طرق الرياض للمقاولات
RIYADH ROADS CONTRACTING CO.

المقاول :- شركة طرق الرياض للمقاولات				الإدارة العامة للتنفيذ والإشراف إدارة تنفيذ الطرق				الإستشاري :- مكتب رمك للإستشارات الهندسية			
تقرير إستلام طبقة ردم											
اسم المشروع :-			كلال الغروب			رقم الشارع :-			ROAD-B10-2		
رقم المخطط :-			BLOCK10			طول الشارع :-			264.33M		
رقم الطبقة :-			BOUOTTOM OF SUPGRADE-1			عرض الشارع :-			18		
			LAYAER THICKNESS			9.000			WIDHT-R		
			DEOTH FROM TOP SUB.G			9.000			WIDHT L		
PVI	Station	Easting	Northing	L		C.L	R		CL width from L	CL width from R	H
SLOPE				1.50%	2.00%	0.00%	2.00%	1.50%			
				-5.000	-3.500	0.000	3.500	5.500			
1	0	529015.6017	2369855.076	51.405	51.322	51.392	51.322	51.405	9.000	9.000	-0.370
2	12.5	529027.1433	2369850.276	51.443	51.360	51.430	51.360	51.443	9.000	9.000	-0.557
3	25	529038.685	2369845.476	51.480	51.397	51.467	51.397	51.480	9.000	9.000	-0.446
4	37.5	529050.2266	2369840.676	51.518	51.435	51.505	51.435	51.518	9.000	9.000	-0.448
5	50	529061.7683	2369835.876	51.555	51.472	51.542	51.472	51.555	9.000	9.000	-0.411
6	62.5	529073.3099	2369831.076	51.593	51.510	51.580	51.510	51.593	9.000	9.000	-0.356
7	75	529084.8516	2369826.276	51.631	51.548	51.618	51.548	51.631	9.000	9.000	-0.286
8	87.5	529096.3932	2369821.476	51.668	51.585	51.655	51.585	51.668	9.000	9.000	-0.330
9	100	529107.9349	2369816.676	51.706	51.623	51.693	51.623	51.706	9.000	9.000	-0.117
10	112.5	529119.4765	2369811.876	51.743	51.660	51.730	51.660	51.743	9.000	9.000	-0.168
11	125	529131.0182	2369807.076	51.781	51.698	51.768	51.698	51.781	9.000	9.000	-0.124
12	137.5	529142.5598	2369802.276	51.819	51.736	51.806	51.736	51.819	9.000	9.000	-0.135
13	150	529154.1015	2369797.476	51.856	51.773	51.843	51.773	51.856	9.000	9.000	-0.228
14	162.5	529165.6431	2369792.676	51.894	51.811	51.881	51.811	51.894	9.000	9.000	-0.152
15	175	529177.1848	2369787.876	51.931	51.848	51.918	51.848	51.931	9.000	9.000	-0.203
16	187.5	529188.7264	2369783.076	51.969	51.886	51.956	51.886	51.969	9.000	9.000	-0.228
17	200	529200.2681	2369778.276	52.007	51.924	51.994	51.924	52.007	9.000	9.000	-0.210
18	212.5	529211.8097	2369773.476	52.044	51.961	52.031	51.961	52.044	9.000	9.000	-0.383
19	225	529223.3514	2369768.676	52.082	51.999	52.069	51.999	52.082	9.000	9.000	-0.474
20	237.5	529234.893	2369763.876	52.119	52.036	52.106	52.036	52.119	9.000	9.000	-0.542
21	250	529246.4347	2369759.076	52.157	52.074	52.144	52.074	52.157	9.000	9.000	-0.530
22	262.5	529257.9763	2369754.276	52.194	52.111	52.181	52.111	52.194	9.000	9.000	-0.413
23	264.33	529259.6676	2369753.572	52.200	52.117	52.187	52.117	52.200	9.000	9.000	-0.370
الإستشاري				المقاول							
مكتب رمك للإستشارات الهندسية				شركة طرق الرياض للمقاولات							
الإسم :- م حسام محمد				الإسم :- عبداللہ حسين							
التوقيع :-				التوقيع :-							
التاريخ :-				التاريخ :-							



In-place Density and Water Content of Soil by EDG

Project	تنفيذ اعمال البنية التحتية	Report No.	PRO-235989/25
Client	شركة طرق الرياض للمقاولات	Report Date	03/10/2024
Location	جدة - حي الامير فواز - مخطط تلال الغروب	E.Conditions	-
Test Apparatus	NL scientific	Ref.	ASTM D 7698

Layer	Bottom Sub Grade
Location	Street 02 Block 10

FIELD TEST RESULTS						
TEST NO.	LOCATION	wet denisty	dry denisty	water content	compaction	percent req.
		kg/m3	kg/m3	%	%	%
1	Bottom Sub Grade	2.300	2.138	7.6	99.4	95
2	Bottom Sub Grade	2.300	2.138	7.6	99.4	95
3	Bottom Sub Grade	2.300	2.138	7.6	99.4	95
4	Bottom Sub Grade	2.300	2.138	7.6	99.4	95
5	Bottom Sub Grade	2.300	2.138	7.6	99.4	95

M.D.D = 2.168 kg/m3
O.M.C = 7.48 %

The lab is responsible of all information provided in this report, unless this information is given by the client.

* These results are for the tested materials and tested locations only.

The lab is not responsible of sampling, sample is tested as received.

The report will not be re issued until authorized by the lab management, Lab is not responsible about the sample after two weeks of the test reoport date.

Checked by
Lab



Approved by
[Signature]



